City of Tempe Development Services Department Building Safety P. O. Box 5002 Tempe, AZ 85280 (480) 350-8341, Option 1



www.tempe.gov

TEMPORARY POWER AT PERMANENT ELECTRICAL SERVICE GUIDELINES AND REQUIREMENTS

Permanent power to a building may be released early for temporary use under certain conditions and for specific uses. Examples of this would be construction power, testing of special equipment, testing of duct smoke detectors, testing of systems for Fire Marshal or Planning final approvals.

All requests for an early release of utilities to a building, for any purpose, shall be made through the Building Inspector assigned to the project. If approved by the Building Inspector, the Inspector will fill out and sign an **Application for Temporary Power**. The owner/authorized agent shall bring the completed **Application for Temporary Power** to the Community Development Department and pay a \$606 non-refundable fee. Applications must have the original wet ink Building Inspector signature, **PHOTO COPIES ARE NOT ACCEPTABLE**.

In most cases, when a project has both electric and natural gas utilities, the Building Inspector may not be able to release both utilities.

Conditions:

- The Application for Temporary Power will serve as the agreement between the owner/authorized agent and the City of Tempe Community Development Department. Any abuse, misuse or violation of this agreement will result in its termination and this department may request that the serving utility disconnect service to the suite and/or building.
- The electric service section (SES) must have lockable disconnect(s)
- The contractor must provide circuit breaker-locking devices
- The gas service must have lockable devices
- Panels(s) and/or circuits(s) must be complete, inspected and approved by the City Building Inspector prior to being energized
- The gas system must be complete, inspected and approved by the City Building Inspector prior to being turned on
- Padlocks may need to be purchased by the requesting party. Check with your Building inspector for padlock availability
- When required, the padlocks(s) purchased must be a Master Lock Model No.
 175SDLH (settable combination type) or equivalent
- The Building Inspector will set the lock(s) combination. The Building Inspector(s) will
 unlock disconnects/circuit breakers as needed and agreed. The lock(s) may become
 the property of the City of Tempe
- The Building Inspection Administrator may, in writing to the responsible contact person, terminate this approval at any time.

DBS 309.01 Effective July 1, 2011